

## Certificate of Product Approval

Licensee:

### **Prysmian Cables & Systems Ltd**

Chickenhall Lane, Eastleigh, SO50 6YU, Hampshire, United Kingdom

Factory:  
Oak Road

Wrexham Industrial Estate, Wrexham, LL13 9PH, Clwyd, United Kingdom

Standard:  
BS 6622:2007 Incorporating Corrigenda Nos. 1 and 2

Description:  
Medium voltage power cables up to 33kV with PVC/MDPE sheathing

Details:  
Stranded circular copper or aluminium class 2 conductors. XLPE insulation. Bonded or strippable semi-conducting insulation screen. Copper tape and/or copper wire screened. Extruded inner sheath. Aluminium round wire armoured (single-core cables). Galvanised steel round wire armoured (3-core cables). Type 9 PVC extruded outer sheath. Voltage ratings: 3.8/6.6 (7.2)kV, 6.35/11(12)kV, 8.7/15 (17.5)kV, 12.7/22 (24)kV and 19/33 (36)kV

Materials:  
Insulation XLPE, Sheath Type 9

Brand Name:  
N/A

Origin Mark:  
PRYSMIAN (W)

#### Permissible Approval Marks:

**BASEC**



BASEC name

BASEC roundel

Signed for and on behalf of the British Approvals Service for Cables

*Tony Lioveri*

Date: 13/01/2021

Date of original issue: 06/02/2020

Check BASEC website to verify validity.

Page 1 of 2

BASEC, Presley House, Presley Way, Milton Keynes, MK8 0ES,

Registered in England No. 1150237, Tel: +44(0)1908267300

Email: mail@basec.org.uk, Web: www.basec.org.uk



Expiry date:  
**11/08/2023**



Type(s) and Range(s) of Approval

Table / Clause	Code Designation	Conductor Class	Range of Cores	Min Nominal Size -sqmm	Max Nominal Size - sqmm
N/A	N/A	Class 2	1	70	1000
N/A	N/A	Class 2	3	70	300

Signed for and on behalf of the British Approvals Service for Cables

*Tony Lioveri*

Date: 13/01/2021

Date of original issue: 06/02/2020

Check BASEC website to verify validity.

Page 2 of 2

BASEC, Presley House, Presley Way, Milton Keynes, MK8 0ES,

Registered in England No. 1150237, Tel: +44(0)1908267300

Email: mail@basec.org.uk, Web: www.basec.org.uk



Expiry date:  
**11/08/2023**