

Certificate of Product Approval

Licensee:

Draka UK Ltd

Chickenhall Lane, Eastleigh, SO50 6YU, Hampshire, United Kingdom

Factory:

Chickenhall Lane, Eastleigh, SO50 6YU, Hampshire, United Kingdom

Standard:

BS 5467:2016 Incorporating Corrigendum No. 1

Description:

Thermosetting insulated, armoured cables with rated voltages of 600/1000V with PVC sheathing

Details:

N/A

Materials:

Insulation GP 8, Sheath Type 9

Brand Name:

N/A

Origin Mark:

DRAKA UK (B)

Permissible Approval Marks:

BASEC



BASEC name

BASEC roundel

Signed for and on behalf of the British Approvals Service for Cables

Tony Lioveri

Date: 17/11/2020

Date of original issue: 06/10/2012

Check BASEC website to verify validity.

Page 1 of 2

BASEC, Presley House, Presley Way, Milton Keynes, MK8 0ES,

Registered in England No. 1150237, Tel: +44(0)1908267300

Email: mail@basec.org.uk, Web: www.basec.org.uk



Expiry date:
11/08/2023



Type(s) and Range(s) of Approval

Table / Clause	Code Designation	Conductor Class	Range of Cores	Min Nominal Size -sqmm	Max Nominal Size -sqmm
5	6942X	Class 2	2	1.5	70
6	6943X	Class 2	3	1.5	70
7	6944X	Class 2	4	1.5	70
8	6945X	Class 2	5	1.5	10
9	6947X	Class 2	7	1.5	4
9	6940/12X	Class 2	12	1.5	4
9	6940/19X	Class 2	19	1.5	4
9	6940/27X	Class 2	27	1.5	4
9	6940/37X	Class 2	37	1.5	4

Signed for and on behalf of the British Approvals Service for Cables

Tony Lioveri

Date: 17/11/2020

Date of original issue: 06/10/2012

Check BASEC website to verify validity.

Page 2 of 2

BASEC, Presley House, Presley Way, Milton Keynes, MK8 0ES,

Registered in England No. 1150237, Tel: +44(0)1908267300

Email: mail@basec.org.uk, Web: www.basec.org.uk



Expiry date:
11/08/2023