



## Certificate of Product Approval

Licensee:

### **Prysmian Cables & Systems Ltd**

Chickenhall Lane, Eastleigh, SO50 6YU, Hampshire, United Kingdom

Factory:

Chickenhall Lane, Eastleigh, SO50 6YU, Hampshire, United Kingdom

Standard:

BS 7629-1:2015

Description:

Fire resistant screened cables

Details:

ENHANCED 120. Additionally tested to BS 6387:2013 Category CWZ.

Materials:

Insulation EI 5, Sheath LTS 3

Brand Name:

FPPLUS

Origin Mark:

PRYSMIAN (B) or (B) PRYSMIAN (FP PLUS)

### Permissible Approval Marks:

**BASEC**

BASEC name



BASEC roundel

Signed for and on behalf of  
BASEC Group Ltd

*Kieran O'Brien* Date: 06/07/2023

Date of original issue: 10/05/1993

Check BASEC website to verify validity.

Page 1 of 2

BASEC Group Ltd, Presley House, Presley Way, Milton Keynes, MK8 0ES, UK  
Registered in England No. 13950143, Tel: +44 (0)1908 267300  
Email: mail@basec.org.uk Web: www.basec.org.uk

BSF079 Issue 5 (20-03-2023)



Expiry date:  
**11/08/2026**



Type(s) and Range(s) of Approval

Table / Clause	Code Designation	Conductor Class	Range of Cores	Min Nominal Size -sqmm	Max Nominal Size - sqmm
2	N/A	Class 1	2	1.5	2.5
2	N/A	Class 1	3	1.5	2.5
2	N/A	Class 1	4	1.5	2.5

Signed for and on behalf of  
BASEC Group Ltd

*Kieran O'Brien* Date: 06/07/2023

Date of original issue: 10/05/1993

Check BASEC website to verify validity.

Page 2 of 2

BASEC Group Ltd, Presley House, Presley Way, Milton Keynes, MK8 0ES, UK  
Registered in England No. 13950143, Tel: +44 (0)1908 267300  
Email: mail@basec.org.uk Web: www.basec.org.uk

BSF079 Issue 5 (20-03-2023)



Expiry date:  
**11/08/2026**