

# **Certificate of Product Approval**

Certificate Number: 1134a lssue: 04

## DRAKA UK LIMITED

Chickenhall Lane Bishopstoke Eastleigh Hants SO50 6YU United Kingdom



### Product(s)

Cable Types as listed below: FT30

See Certificate Appendix for details

### **Standard(s) (see Appendix for details)**

BS 7629-1:2015 (STANDARD 60) BS 6387:2013 (C,W,Z)

EN 50200:2015 (Class PH120)

EN 50200:2015 Annex E (30 mins)

BS 5839-1:2013 (Clause 26.2d Standard)

This Certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 Certificate being maintained.

Damier Ward

Damien Ward

12 August 2016

19 February 2013

Signed for LPCB

Certification Scheme Manager

Date of Issue

Date of First issue





This certificate and appendix remain the property of BRE Global Ltd and is issued subject to terms and conditions (for details visit <a href="https://www.redbooklive.com/terms">www.redbooklive.com/terms</a>).

To check the validity of this certificate and appendix please visit <a href="https://www.redbooklive.com/check">www.redbooklive.com/check</a>, scan the QR tag or contact us.

LPCB is part of BRE Global Ltd, Garston, Watford, WD25 9XX T: +44 (0)333 321 8811 F: +44 (0)1923 664603 E: enquiries@breglobal.com







## Appendix to Certificate No: 1134a **DRAKA UK LIMITED**

LPCB Ref. Product name 1134a/01 FT30

Nominal csa of conductor (mm²)	Core Construction (excluding drain wire & earth)	BS 7629-1	BS 6387	EN 50200	EN 50200 (Annex E)	EN 5839-1 (clause 26.2)
1.5	2, 3 & 4 <sup>(1,3)</sup>	STANDARD 60 <sup>(4)</sup>	C,W,Z	PH120	30min <sup>(5)</sup>	Standard <sup>(6)</sup>
2.5	2, 3 & 4 <sup>(1,3)</sup>	STANDARD 60 <sup>(4)</sup>	C,W,Z	PH120	30min <sup>(5)</sup>	Standard <sup>(6)</sup>
4.0	2, 3 & 4 <sup>(2,3)</sup>	STANDARD 60 <sup>(4)</sup>	C,W,Z	PH120	30min <sup>(5)</sup>	Standard <sup>(6)</sup>

### Uo/U 300/500V

#### Notes:

- Solid conductor only.
  Stranded conductor only.
- 3. All cables have the blue core designated as a Neutral conductor; only phase to earth voltage was applied to the
- 4. In meeting the requirements of BS 7629-1:2015, the FT30 cables listed met the requirements for smoke density of EN 61034-2:2005+A1:2013, and achieved less than 0.5% HCl for the insulation, binder tape, and outer covering when tested in accordance with EN 60754-1:2014 and in addition also met the fire resistance requirements of BS 6387:2013 Categories CWZ.
- 5. The duration of 30min when tested in accordance with EN 50200:2015 Annex E is achieved by 15min for the fire and mechanical shock phase and an additional 15min for the fire, mechanical shock and water phase.
- 6. The FT30 cables listed conform to BS 7629-1:2015, met Class PH120 when tested in accordance with EN 50200:2015 and met the 30min duration when tested in accordance with EN 50200:2015 Annex E and hence met the requirements for a standard fire resistant cable as described in Clause 26.2 of BS 5839-1:2013.

This Certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 Certificate being maintained.

Damier Ward

Damien Ward

12 August 2016

19 February 2013

Signed for LPCB

Certification Scheme Manager

Date of Issue

Date of First issue





This certificate and appendix remain the property of BRE Global Ltd and is issued subject to terms and conditions (for details visit www.redbooklive.com/terms).

To check the validity of this certificate and appendix please visit www.redbooklive.com/check, scan the QR tag or contact us.

LPCB is part of BRE Global Ltd, Garston, Watford, WD25 9XX T: +44 (0)333 321 8811 F: +44 (0)1923 664603 E: enquiries@breglobal.com





Issue: 04